

## Mannok Insulation Limited

Scotchtown  
Ballyconnell  
Co Cavan  
Ireland

Tel: 00 353 49 9525600

e-mail: [info@mannokbuild.com](mailto:info@mannokbuild.com)

website: [www.mannokbuild.com](http://www.mannokbuild.com)



### Agrément Certificate

07/4444

Product Sheet 3 Issue 3

## MANNOK INSULATION

### MANNOK THERM FLOOR / MF – INSULATED FOIL FACED UNDERFLOOR BOARD

This Agrément Certificate Product Sheet<sup>(1)</sup> relates to Mannok Therm Floor / MF – Insulated Foil-Faced Underfloor Board, comprising a rigid polyisocyanurate (PIR) foam board with composite foil-facings. The product is for use as thermal insulation of ground-bearing or suspended concrete ground-floors or between the joists of suspended timber ground-floors, in new or existing domestic buildings.

(1) Hereinafter referred to as 'Certificate'.

#### The assessment includes

##### Product factors:


- compliance with Building Regulations
- compliance with additional regulatory or non-regulatory information where applicable
- evaluation against technical specifications
- assessment criteria and technical investigations
- uses and design considerations

##### Process factors:

- compliance with Scheme requirements
- installation, delivery, handling and storage
- production and quality controls
- maintenance and repair

##### Ongoing contractual Scheme elements†:

- regular assessment of production
- formal 3-yearly review



#### KEY FACTORS ASSESSED

- Section 1. Mechanical resistance and stability
- Section 2. Safety in case of fire
- Section 3. Hygiene, health and the environment
- Section 4. Safety and accessibility in use
- Section 5. Protection against noise
- Section 6. Energy economy and heat retention
- Section 7. Sustainable use of natural resources
- Section 8. Durability

The BBA has awarded this Certificate to the company named above for the product described herein. This product has been assessed by the BBA as being fit for its intended use provided it is installed, used and maintained as set out in this Certificate.

On behalf of the British Board of Agrément

Date of Third issue: 10 January 2024

Originally certificated on 18 November 2011

Hardy Giesler  
Chief Executive Officer

*This BBA Agrément Certificate is issued under the BBA's Inspection Body accreditation to ISO/IEC 17020. Sections marked with † are not issued under accreditation.*

*The BBA is a UKAS accredited Inspection Body (No. 4345), Certification Body (No. 0113) and Testing Laboratory (No. 0357).*

*Readers MUST check that this is the latest issue of this Agrément Certificate by either referring to the BBA website or contacting the BBA directly.*

*The Certificate should be read in full as it may be misleading to read clauses in isolation.*

*Any photographs are for illustrative purposes only, do not constitute advice and should not be relied upon.*

#### British Board of Agrément

1<sup>st</sup> Floor Building 3  
Croxley Park, Watford  
Herts WD18 8YG

©2024

tel: 01923 665300  
[clientservices@bbacerts.co.uk](mailto:clientservices@bbacerts.co.uk)  
[www.bbacerts.co.uk](http://www.bbacerts.co.uk)

## SUMMARY OF ASSESSMENT AND COMPLIANCE

This section provides a summary of the assessment conclusions; readers should refer to the later sections of this Certificate for information about the assessments carried out.

### Compliance with Regulations

Having assessed the key factors, the opinion of the BBA is that Mannok Therm Floor / MF – Insulated Foil-Faced Underfloor Board, if installed, used and maintained in accordance with this Certificate, can satisfy or contribute to satisfying the relevant requirements of the following Building Regulations:



#### The Building Regulations 2010 (England and Wales) (as amended)

<b>Requirement:</b>	<b>A1</b>	<b>Loading</b>
Comment:		The product can contribute to satisfying this Requirement. See section 1 of this Certificate.
<b>Requirement:</b>	<b>C2(c)</b>	<b>Resistance to moisture</b>
Comment:		The product can contribute to satisfying this Requirement. See section 3 of this Certificate.
<b>Requirement:</b>	<b>L1(a)(i)</b>	<b>Conservation of fuel and power</b>
Comment:		The product can contribute to satisfying this Requirement; however, compensating fabric measures may be required. See section 6 of this Certificate.
<b>Regulation:</b>	<b>7(1)</b>	<b>Materials and workmanship</b>
Comment:		The product is acceptable. See sections 8 and 9 of this Certificate.
<b>Regulation:</b>	<b>25B</b>	<b>Nearly zero-energy requirements for new buildings</b>
<b>Regulation:</b>	<b>26</b>	<b>CO<sub>2</sub> emission rates for new buildings</b>
<b>Regulation:</b>	<b>26A</b>	<b>Fabric energy efficiency rates for new dwellings (applicable to England only)</b>
<b>Regulation:</b>	<b>26A</b>	<b>Primary energy rates for new buildings (applicable to Wales only)</b>
<b>Regulation:</b>	<b>26B</b>	<b>Fabric performance values for new dwellings (applicable to Wales only)</b>
<b>Regulation:</b>	<b>26C</b>	<b>Target primary energy rates for new buildings (applicable to England only)</b>
<b>Regulation:</b>	<b>26C</b>	<b>Energy efficiency rating (applicable to Wales only)</b>
Comment:		The product can contribute to satisfying these Regulations; however, compensating fabric/service measures may be required. See section 6 of this Certificate.



#### The Building (Scotland) Regulations 2004 (as amended)

<b>Regulation:</b>	<b>8(1)</b>	<b>Fitness and durability of materials and workmanship</b>
Comment:		The product is acceptable. See sections 8 and 9 of this Certificate.
<b>Regulation:</b>	<b>9</b>	<b>Building standards - construction</b>
<b>Standard:</b>	<b>1.1(b)</b>	<b>Structure</b>
Comment:		The product can contribute to satisfying this Standard, with reference to clause 1.1.1 <sup>(1)</sup> . See section 1 of this Certificate.
<b>Standard:</b>	<b>3.15</b>	<b>Condensation</b>
Comment:		The product can contribute to satisfying this Standard, with reference to clauses 3.15.1 <sup>(1)</sup> , 3.15.4 <sup>(1)</sup> and 3.15.5 <sup>(1)</sup> . See section 3 of this Certificate.
<b>Standard:</b>	<b>6.1(b)(c)</b>	<b>Energy demand and carbon dioxide emissions</b>
Comment:	<b>(d)</b>	The product can contribute to satisfying this Standard with reference to clauses 6.1.1 <sup>(1)</sup> and 6.1.6 <sup>(1)</sup> , however, compensating fabric/service measures may be required. See section 6 of this Certificate.

Standard:	6.2	Building insulation envelope
Comment:		The product can contribute to satisfying this Standard with reference to clauses 6.2.1 <sup>(1)</sup> , 6.2.3 <sup>(1)</sup> , 6.2.6 <sup>(1)</sup> , 6.2.7 <sup>(1)</sup> , 6.2.8 <sup>(1)</sup> , 6.2.9 <sup>(1)</sup> , 6.2.10 <sup>(1)</sup> , 6.2.11 <sup>(1)</sup> and 6.2.12 <sup>(1)</sup> ; however, compensating fabric measures may be required. See section 6 of this Certificate.
Standard:	7.1(a)(b)	Statement of sustainability
Comment:		The product can contribute to satisfying the relevant requirements of Regulation 9, Standards 1 to 6, and therefore will contribute to a construction meeting at least a bronze level of sustainability as defined in this Standard. In addition, the product can contribute to a construction meeting a higher level of sustainability as defined in this Standard, with reference to clauses 7.1.2 <sup>(1)</sup> , 7.1.4 <sup>(1)</sup> , 7.1.6 <sup>(1)</sup> and 7.1.7 <sup>(1)</sup> . See section 6 of this Certificate.
Regulation:	12	<b>Building standards - conversions</b>
Comment:		All comments given for the product under Regulation 9, Standards 1 to 6, also apply to this Regulation, with reference to clause 0.12.1 <sup>(1)</sup> and Schedule 6 <sup>(1)</sup> .
(1) Technical Handbook (Domestic).		



## The Building Regulations (Northern Ireland) 2012 (as amended)

Regulation:	23(1)(a)(i)	<b>Fitness of materials and workmanship</b>
Comment:	(iii)(b)(i)(ii)	The product is acceptable. See sections 8 and 9 of this Certificate.
Regulation:	29	<b>Condensation</b>
Comment:		The product can contribute to satisfying this Regulation. See section 3 of this Certificate.
Regulation:	30	<b>Stability</b>
Comment:		The product can contribute to satisfying this Regulation. See section 1 of this Certificate.
Regulation:	39(a)(i)	<b>Conservation measures</b>
Comment:		The product can contribute to satisfying this Regulation; however, compensating fabric/services measures may be required. See section 6 of this Certificate.
Regulation:	40(2)	<b>Target carbon dioxide emission rate</b>
Regulation:	43(1)(2)	<b>Renovation of thermal elements</b>
Regulation:	43B	<b>Nearly zero-energy requirements for new buildings</b>
Comment:		The product can contribute to satisfying these Regulations; however, compensating fabric/services measures may be required. See section 6 of this Certificate.

## Additional Information

### NHBC Standards 2024

In the opinion of the BBA, Mannok Therm Floor / MF – Insulated Foil-Faced Underfloor Board, if installed, used and maintained in accordance with this Certificate, can satisfy or contribute to satisfying the relevant requirements in relation to *NHBC Standards*, Chapters 5.1 *Substructure and ground bearing floors* and 5.2 *Suspended ground floors*.

## Fulfilment of Requirements

The BBA has judged Mannok Therm Floor / MF – Insulated Foil-Faced Underfloor Board to be satisfactory for use as described in this Certificate. The product has been assessed as insulation in ground-bearing or suspended concrete ground floors, or between the joists of suspended timber ground floors, in new or existing domestic buildings.

## ASSESSMENT

### Product description and intended use

The Certificate holder provided the following description for the product under assessment. Mannok Therm Floor / MF – Insulated Foil-Faced Underfloor Board consists of rigid PIR foam boards with composite foil-facings.

The product has the nominal characteristics given in Table 1.

*Table 1 Nominal characteristics*

Characteristic (unit)	Value
Board size (mm)	2400 x 1200
Thickness (mm)	20 to 200 (in 5 mm increments)
Edge profile	Square
Facings	Composite foil-facing both sides (printed on one side only) <sup>(1)</sup>
Flatness (deviation from flatness – mm)	
area ≤ 0.75 m <sup>2</sup>	≤ 5
area > 0.75 m <sup>2</sup>	≤ 10

(1) See section 9.1.10 of this Certificate.

#### Ancillary Items

The Certificate holder recommends the following ancillary items for use with the product, but these materials have not been assessed by the BBA and are outside the scope of this Certificate:

The overlay to the products should be:

- an air and vapour control layer (AVCL) where necessary (see section 3 of this Certificate) and:
- a cement-based floor screed of minimum 65 mm<sup>(1)</sup> thickness, laid in accordance with the relevant clauses of BS 8204-1 : 2003 and/or BS 8204-2 : 2003, and BS 8000-9 : 2003 or
- wood-based floor [eg tongue-and-groove plywood to BS EN 636 : 2012, flooring grade particle board (Type P4 or P7) to BS EN 312 : 2010 or oriented strand board (type OSB/3 to OSB/4) to BS EN 300 : 2006], of a thickness to be determined by a suitably competent and experienced individual, and installed in accordance with PD CEN/TR 12872 : 2014 and BS EN 12871 : 2013 or
- a concrete slab to BS EN 1992-1-1 : 2004 and its UK National Annex.

(1) The NHBC only accepts ground-supported floor slabs with at least 100 mm thick concrete including a monolithic screed.

### Product assessment – key factors

The product was assessed for the following key factors, and the outcome of the assessments is shown below. Conclusions relating to the Building Regulations apply to the whole of the UK unless otherwise stated.

## 1 Mechanical resistance and stability

Data were assessed for the following characteristics.

### 1.1 Behaviour under loading

1.1.1 The product was tested for compressive strength and the results are given in Table 2.

**Table 2 Compressive strength**

Product assessed	Assessment method	Requirement	Result
Mannok Therm Floor / MF – Insulated Foil-Faced Underfloor Board	BS EN 826 : 1996	Declared minimum compressive strength of the product at 10% deformation	≥ 150 kPa

1.1.2 On the basis of data assessed, the product is suitable for the occupancies defined in this Certificate when covered with a suitable floor overlay, and is capable of resisting a uniformly distributed load of  $1.5 \text{ kN}\cdot\text{m}^{-2}$  or a concentrated load of 2 kN for category A1 and A2 (domestic) situations as defined in the UK National Annex to BS EN 1991-1-1 : 2002, Table NA.2.

1.1.3 The performance of a specific floor construction will depend on the insulation properties and type of floor overlay used (including thickness and strength). When the product is used under a concrete slab, resistance to concentrated and distributed loads is a function of the slab specification. Further guidance on the suitability of floor overlays can be found in BS EN 13810-1 : 2002, DD CEN/TS 13810-2 : 2003, BS 8204-1 : 2003 and BS EN 312 : 2010, and from the flooring manufacturer, although the latter is outside the scope of this Certificate.

## 2 Safety in case of fire

Data were assessed for the following characteristics.

### 2.1 Reaction to fire

2.1.1 The product was tested for reaction to fire and the classification is given in Table 3.

**Table 3 Reaction to fire classification**

Product assessed	Assessment method	Requirement	Result
Mannok Therm Floor / MF Underfloor Board	UNE-EN 13501-1 : 2019	Reaction to fire classification	E <sup>(1)</sup>

(1) Test report 21/24307-1373-2 M4 (Issued 19 December 2022 by Applus Laboratories). Copies are available from the Certificate holder on request.

2.1.2 Where an intermediate floor incorporating the product is required to achieve a period of fire resistance, its performance must be confirmed by a suitably competent and experienced individual or by a test from a suitably accredited laboratory.

## 3 Hygiene, health and the environment

Data were assessed for the following characteristics.

### 3.1 Water vapour permeability

3.1.1 For the purposes of assessing the risk of interstitial condensation, the water vapour resistance/resistivity values may be taken as given in Table 4.

**Table 4 Water vapour resistance/resistivity**

Material	Assessment method	Requirement	Result
PIR insulation	BS EN ISO 10456 : 2007	Declared value	$300 \text{ MN}\cdot\text{s}\cdot\text{g}^{-1}\cdot\text{m}^{-1}$
Foil facer	BS 5250 : 2021		$1000 \text{ MN}\cdot\text{s}\cdot\text{g}^{-1}$

### 3.2 Condensation

3.2.1 The BBA has assessed the product for the risk of interstitial condensation, and the following factors must be implemented:

3.2.1.1 When the product is used on a ground-bearing floor or a suspended concrete floor, an AVCL must be installed on the warm side of the insulation to inhibit the risk of interstitial condensation, unless a risk assessment shows this is not necessary.

3.2.1.2 Voids below suspended timber ground floors must be ventilated. Ventilation may be achieved by installing vents not less than  $1500 \text{ mm}^2 \cdot \text{m}^{-1}$  run of external wall or  $500 \text{ mm}^2 \cdot \text{m}^{-2}$  of floor area, whichever is the greater. Ventilation openings must be arranged to prevent the ingress of rain, snow, birds and small mammals and the risk of subsequent blockage by other building operations.

## 4 Safety and accessibility in use

Not applicable.

## 5 Protection against noise

Not applicable.

## 6 Energy economy and heat retention

Data were assessed for the following characteristics.

### 6.1 Thermal conductivity

The product was tested for thermal conductivity and the result is given in Table 5.

Table 5 Thermal conductivity				
Product assessed	Insulation thickness	Assessment method	Requirement	Result
Mannok Therm Floor / MF – Insulated Foil-Faced Underfloor Board	20 to 200 mm	Thermal conductivity to BS EN 13165 : 2012	Declared value ( $\lambda_D$ )	$0.022 \text{ W} \cdot \text{m}^{-1} \cdot \text{K}^{-1}$

### 6.2 Thermal performance

6.2.1 The facings were tested for emissivity and the results are given in Table 6.

Table 6 Emissivity of the facings			
Product assessed	Assessment method	Requirement	Result
Mannok Therm Floor / MF foil facings	Aged emissivity to BS EN 15976 : 2011	Declared value	0.03

6.2.2 The U-value of a completed floor will depend on the insulation thickness, the perimeter/area ratio, and the floor type. Example U-values are given in Table 7.

**Table 7 Example U-values<sup>(1)</sup> — ground-floor construction**

Floor Type	Target U-value (W·m <sup>-2</sup> ·K <sup>-1</sup> )	Insulation thickness (mm)				
		P/A ratio				
		0.2	0.4	0.6	0.8	1.0
Ground-bearing concrete floor <sup>(1)(4)</sup>	0.11	120	150	160	165	170
	0.12	105	135	145	150	155
	0.13	90	120	130	135	140
	0.15	70	100	110	115	120
	0.18	50	75	90	95	95
	0.22	30	55	65	70	75
	0.25	20	45	55	60	65
Suspended concrete ground-floor <sup>(2)(4)</sup>	0.11	135	155	160	165	170
	0.12	120	140	145	150	155
	0.13	110	125	135	140	140
	0.15	85	105	115	115	120
	0.18	65	85	90	95	95
	0.22	45	60	70	70	75
	0.25	30	50	55	60	65
Suspended timber ground-floor <sup>(3)</sup>	0.11	200	_(5)	_(5)	_(5)	_(5)
	0.12	180	_(5)	_(5)	_(5)	_(5)
	0.13	160	190	200	_(5)	_(5)
	0.15	125	155	165	170	175
	0.18	90	120	130	135	140
	0.22	60	90	100	105	110
	0.25	45	70	80	85	90

(1) Ground-bearing concrete floor construction (Mannok Therm Floor / MF on top of slab, under screed finish) 65 mm concrete screed ( $\lambda = 1.15 \text{ W} \cdot \text{m}^{-1} \cdot \text{K}^{-1}$ ), polyethylene separating layer, Mannok Therm Floor / MF, damp-proof membrane (DPM), 100 mm concrete oversite, 150 mm sand-blinded hardcore, ground ( $\lambda = 1.5 \text{ W} \cdot \text{m}^{-1} \cdot \text{K}^{-1}$ ).

(2) Suspended concrete ground-floor construction (Mannok Therm Floor / MF) on top of beam and block, below screed finish) – 65 mm concrete screed ( $\lambda = 1.15 \text{ W} \cdot \text{m}^{-1} \cdot \text{K}^{-1}$ ), polyethylene separating layer, Mannok Therm Floor / MF, beam and block floor (12%) Beam ( $\lambda = 2.00 \text{ W} \cdot \text{m}^{-1} \cdot \text{K}^{-1}$ ), dense block infill ( $\lambda = 1.13 \text{ W} \cdot \text{m}^{-1} \cdot \text{K}^{-1}$ ), ventilated void.

(3) Suspended timber ground-floor construction (Mannok Therm Floor / MF between floor joists) – floor deck based on 22 mm chipboard ( $\lambda = 0.13 \text{ W} \cdot \text{m}^{-1} \cdot \text{K}^{-1}$ ), Mannok Therm Floor / MF (89%) between 47 mm wide joists at 400 mm centres. The depth of the joists = 100 to 200 mm depending on the depth of insulation between timber ( $\lambda = 0.13 \text{ W} \cdot \text{m}^{-1} \cdot \text{K}^{-1}$ ) floor joists (11%) based on BRE Report BR 443 : 2019 (38 mm wide nogging every 3 metres).

(4) 30 mm edge insulation of Mannok Therm Floor / MF, 65 mm deep.

(5) See section 6.2.4.

6.2.3 The product can contribute towards a construction satisfying the national Building Regulations in respect of energy economy and heat retention.

6.2.4 For improved energy or carbon savings, designers must consider appropriate fabric / service measures.

## 7 Sustainable use of natural resources

Not applicable.

## 8 Durability

8.1 The potential mechanisms for degradation and the known performance characteristics of the materials in the product were assessed.

8.2 Specific test data were assessed as given in Table 8.

**Table 8 Results of durability tests**

Product assessed	Assessment method	Requirement	Declared level / value
Mannok Therm Floor / MF– Insulated Foil-Faced Underfloor Board	Dimensional stability to BS EN 1604 : 2013 (70°C and 90-100% RH for 48 hours)	Declared value	DS(70,90)4
	Dimensional stability to BS EN 1604 : 2013 (-20°C for 48 hours)		DS(-20,-)2
Unprinted foil-facing	Aged emissivity to BS EN 15976 : 2011		0.03

### 8.3 Service life

Under normal service conditions, the product will have a life equivalent to the structure in which it is incorporated, provided it is designed, installed and maintained in accordance with this Certificate and the Certificate holder's instructions.

## PROCESS ASSESSMENT

Information provided by the Certificate holder was assessed for the following factors:

## 9 Design, installation, workmanship and maintenance

### 9.1 Design

9.1.1 The design process was assessed by the BBA, and the following requirements apply in order to satisfy the performance assessed in this Certificate.

9.1.2 The product can be used on suitably designed beam-and-block floors incorporating Type R2 semi-resisting or resisting blocks to BS EN 15037-2 : 2009 and self-bearing beams to BS EN 15037-1 : 2008.

9.1.3 Ground-bearing floors must only be used where the depth of compacted fill is less than 600 mm and is defined as non-shrinkable. Shrinkable fills are defined as material containing more than 35% fine particles (silt and clay) with a plasticity index of 10% or greater (shrinkable fills are susceptible to clay heave).

9.1.4 Ground-bearing concrete and suspended concrete ground-floors incorporating the product must include a suitable DPM, laid beneath the insulation, in accordance with the relevant sections of CP 102 : 1973, BS 8102 : 2009 and BS 8215 : 1991.

9.1.5 Suspended concrete or timber ground-floors incorporating the product must include suitable ventilation of the sub-floor void (minimum 150 mm void between the underside of the floor and the ground surface) or a DPM. For suspended floors in locations where clay heave is anticipated, an additional void of up to 150 mm may be required to accommodate the possible expansion of the ground below the floor. In such cases where the risk of clay heave has been confirmed by geotechnical investigations by a suitably competent and experienced individual, a total void of up to 300 mm may be required.

9.1.6 Where a concrete screed or slab finish is to be laid directly over the product, a polyethylene separating layer/AVCL must be installed between the insulation and the concrete to prevent chemical attack and seepage between the boards (see section A.7). Any gaps between insulation boards or around service openings, visible prior to installing the concrete, must be filled with expanding foam or strips of insulation.

9.1.7 Internal walls must not be built on the insulation.

9.1.8 If present, mould or fungal growth must be treated prior to the application of the product.

9.1.9 Care must be taken in the overall design and construction of junctions with other elements and openings to minimise thermal bridges and air infiltration and the detailed guidance that can be found in the documents supporting the national Building Regulations must be followed.



9.1.10 When used as insulation in suspended timber ground-floors, for optimum thermal performance, the product must be installed with the correct orientation of its unprinted foil-facing, with the unprinted foil-face always facing the cavity side.

#### *Interstitial condensation*

9.1.11 Floors will adequately limit the risk of interstitial condensation when they are designed and constructed in accordance with BS 5250 : 2021.

9.1.12 When the product is used above the DPM on a ground-bearing floor or suspended concrete floor, an AVCL is installed on the warm side of the insulation to inhibit the risk of interstitial condensation, unless a risk assessment shows this is not necessary.

9.1.13 For suspended timber ground floors, it is not necessary to introduce an AVCL as long as adequate sub-floor cross ventilation is provided.

#### *Surface condensation*

9.1.14 In England and Wales, floors will adequately limit the risk of surface condensation when the thermal transmittance (U value) does not exceed  $0.7 \text{ W}\cdot\text{m}^{-2}\cdot\text{K}^{-1}$  at any point, and the junctions with walls are designed in accordance with section 6 of this Certificate.

9.1.15 In Scotland, floors will adequately limit the risk of surface condensation when the thermal transmittance (U-value) does not exceed  $1.2 \text{ W}\cdot\text{m}^{-2}\cdot\text{K}^{-1}$  at any point and the floor is designed and constructed in accordance with the relevant parts of BS 5250 : 2021.

9.1.16 Further guidance may be obtained from BRE Report BR 262 : 2002 and section 6 of this Certificate.

## 9.2 Installation

9.2.1 Installation instructions provided by the Certificate holder were assessed and judged to be appropriate and adequate.

9.2.2 Installation must be carried out in accordance with this Certificate and the Certificate holder's instructions. A summary of instructions and guidance are provided in Annex A of this Certificate.

#### *Incorporation of services*

9.2.3 De-rating of electrical cables must be considered where the insulation restricts air cooling of cables; the product must not be used in direct contact with electrical heating cables or hot water pipes. Where underfloor heating systems are to be used, the advice of the Certificate holder should be sought, but such advice is outside the scope of this Certificate.

9.2.4 Where possible, electrical conduits, gas and water pipes or other services must be contained within ducts or channels within the concrete slab of ground bearing floors. Where this is not possible, the services may be accommodated within the insulation, provided they are securely fixed to the concrete slab. Electrical cables that are likely to come into contact with the insulation must be protected by a suitable conduit or PVC-U trunking. With hot pipes, the insulation must be cut back to maintain an air space.

9.2.5 Where water pipes are installed below the insulation, they must be pre-lagged with close-fitting pipe insulation.

9.2.6 Where the product is installed on a floor of a suspended beam-and-block design, all services must be installed in accordance with a BBA Certificate for that floor and/or with the relevant codes of practice.

9.2.7 To provide support for a particle board cover on overlay board floors where access to the services is desirable, a duct may be formed by mechanically fixing to the floor, timber bearers of the same thickness as the insulation. The duct must be as narrow as possible and not exceed 400 mm in width or the maximum particle board spans given in DD CEN/TR 12872 : 2014 without intermediate support. Services must be suitably fixed to the floor base and not to the insulation boards.

9.2.8 On suspended timber ground floors, all the services must be incorporated beneath the existing floor, if possible.

### 9.3 Workmanship

Practicability of installation was assessed by the BBA, on the basis of the Certificate holder's information. To achieve the performance described in this Certificate, installation of the product must be carried out by a competent general builder, or a contractor, experienced with this type of product.

### 9.4 Maintenance and repair

As the product is confined within the floor by the overlay and has suitable durability, maintenance is not required.

## **10 Manufacture**

10.1 The production processes for the product have been assessed, and provide assurance that the quality controls are satisfactory according to the following factors:

10.1.1 The manufacturer has provided documented information on the materials, processes, testing and control factors.

10.1.2 The quality control operated over batches of incoming materials has been assessed and deemed appropriate and adequate.

10.1.3 The quality control procedures and product testing to be undertaken have been assessed and deemed appropriate and adequate.

10.1.4 The process for management of non-conformities has been assessed and deemed appropriate and adequate.

10.1.5 An audit of each production location was undertaken, and it was confirmed that the production process was in accordance with the documented process, and that equipment has been properly tested and calibrated.

† 10.2 The BBA has undertaken to review the above measures on a regular basis through a surveillance process, to verify that the specifications and quality control operated by the manufacturer are being maintained.

## **11 Delivery and site handling**

11.1 The Certificate holder stated that the product is delivered to site in packaging bearing the product name, the Certificate holder's name, batch number, and the BBA logo incorporating the number of this Certificate.

11.2 Delivery and site handling must be performed in accordance with the Certificate holder's instructions and this Certificate, including:

11.2.1 The product must be stored such that it is raised off the ground, inside or under cover on a flat, dry, level surface in a well-ventilated area. The product must be protected from rain, snow, and prolonged exposure to sunlight. Nothing must be stored on top of the boards.

11.2.2 Care must be taken when handling the boards to avoid crushing the edges or corners.

11.2.3 The product must not be exposed to open flame or other ignition sources, or solvents or other chemicals.

11.2.4 If damaged or wet, the product must be discarded.

## ANNEX A – SUPPLEMENTARY INFORMATION †

Supporting information in this Annex is relevant to the product but has not formed part of the material assessed for the Certificate.

### Construction (Design and Management) Regulations 2015

### Construction (Design and Management) Regulations (Northern Ireland) 2016

Information in this Certificate may assist the client, designer (including Principal Designer) and contractor (including Principal Contractor) to address their obligations under these Regulations.

### CE marking

The Certificate holder has taken the responsibility of CE marking the product, in accordance with harmonised European Standard EN 13165 : 2012.

### Management Systems Certification for production

The management system of the manufacturer has been assessed and registered as meeting the requirements of BS EN ISO 9001 : 2015 by Certification Europe (Certificate 2005/262 A/8).

### Additional information on installation

A.1 In ground-bearing concrete floors, the concrete floor slab over which the product is laid should be left for as long as possible to maximise drying out and dissipation of constructional moisture, in accordance with BS 8203 : 2017, Section 3.1.2.

A.2 The concrete floor surface should be smooth, level and flat to within 5 mm when measured with a two-metre straight-edge. Irregularities greater than this must be removed. Minor irregularities (up to 10 mm deep) may be levelled with mortar or thin screed.

A.3 Where the insulation is used over ground-bearing concrete floor slabs, a suitable DPM in accordance with CP 102 : 1973 should be laid to resist moisture from the ground. If a liquid-type DPM is applied to the slabs, it should be of a type compatible with the insulation product and be allowed to dry out fully before laying the insulation.

A.4 Where the insulation is used on hardcore bases beneath ground-bearing concrete slabs, the hardcore must be compacted and blinded with a thin layer of sand before application of the DPM followed by the insulation boards.

A.5 An AVCL is installed on the warm side of the insulation to inhibit the risk of interstitial condensation if necessary (see section 3 of this Certificate). Where a concrete screed or slab finish is to be laid directly over the product, a polyethylene separating layer/AVCL must be installed between the insulation and the concrete to prevent chemical attack and seepage between the boards.

A.6 Where a screed or concrete slab is laid over the insulation, vertical upstands of insulation should be provided and be of sufficient depth to fully separate the screed or slab from the wall. If used, a suitable cavity wall insulation material should be extended below the DPC level to provide edge insulation to the floor.

A.7 To limit the risk of condensation and other sources of dampness, the insulation and overlays should only be laid after the construction is made substantially weathertight, eg after glazing. During construction, the insulation and overlay must be protected from damage by traffic and moisture sources such as water spillage and plaster droppings.

A.8 In suspended timber floors, the insulation boards may be installed between the timber floor joists using saddle clips or timber beads. Mannok Therm Floor / MF – Insulated Foil-Faced Underfloor Board has printed logos applied to the outer foil-facing on one side only. To ensure optimum thermal performance, the product must be installed with the unprinted foil-face always facing the cavity side. Tongue-and-groove particle board flooring or softwood floor boarding is then installed in the conventional manner.


## Procedure

A.9 The boards are cut to size using a sharp knife or fine toothed saw as necessary, and laid with closely butted, staggered cross-joints, ensuring all spaces are completely filled.


A.10 The laying pattern should ensure that all cut edges are at the perimeter of the floor or some other feature, eg matwells, thresholds or access ducts. Spreader boards should be used to protect the insulation.

A.11 Typical methods of installation are shown in Figures 1 to 4. Reference should also be made to BRE Report BR 262 : 2002.


*Figure 1 Over a ground-bearing concrete floor*




*Figure 2 Under a ground-bearing concrete slab*



**Figure 3 Over a beam-and-block suspended concrete floor**



**Figure 4 Between the joists in a suspended timber ground-floor**



#### **Cement-based screed overlay (Figures 1 and 3)**

A.12 Perimeter edge pieces are cut and placed around the edges and taped at joints. A polyethylene AVCL, at least 0.125 mm thick (500 gauge), is laid over the insulation. The AVCL should have 150 mm overlaps, taped at the joints and be turned up 100 mm at the walls. A properly compacted screed of a minimum 65 mm thickness is then laid over. The relevant clauses of BS 8204-1 : 2003 should be followed.

#### **Concrete slab overlay (ground-bearing only) (Figure 2)**

A.13 Perimeter edge pieces are cut and placed around the edges and taped at joints. A polyethylene AVCL, at least 0.125 mm thick (500 gauge), is laid over the insulation. The AVCL should have 150 mm overlaps, taped at the joints, and be turned up 100 mm at the walls. The concrete slab is laid to the required thickness in accordance with BS 8000-9 : 2003 and BS 8204-1 : 2003.

## **Timber based board overlay**

A.14 Before laying the plywood, particle board or OSB overlays, preservative-treated timber battens, in accordance with BS 8417 : 2011, are positioned at doorways and access panels. Adequate time should be allowed for preservatives to be fixed, and the solvents from solvent-based preservatives to evaporate.

A.15 Where the insulation is laid above a DPM, a polyethylene AVCL of at least 0.125 mm (500 gauge) thickness is laid between the insulation and the timber board overlay. The AVCL should have 150 mm overlaps, taped at the joints and turned up 100 mm at the walls.

A.16 Timber-based overlay boards are laid with staggered cross-joints, in accordance with DD CEN/TR 12872 : 2014 and BS EN 12871 : 2013.

A.17 An expansion gap between the overlay board and the perimeter walls should be provided at the rate of 2 mm per metre run or a minimum of 10 mm, whichever is the greater.

A.18 Where there are long, uninterrupted lengths of floors (eg corridors), proprietary expansion joints should be installed at intervals on the basis of a 2 mm gap per metre run of overlay board.

A.19 Before the overlay boards are interlocked, a waterproof PVA adhesive is applied to the joints.

A.20 Once the overlay board is laid, temporary wedges are inserted between the walls and the floor overlay to maintain tight joints until the adhesive has set.

A.21 When the wedges are removed and before the skirting boards are fixed, suitable compressible filler, eg foamed polyethylene, should be fitted around the perimeter of the floor between the overlay board and the walls.

A.22 Where there is a likelihood of regular water spillage (eg in kitchens, bathrooms, shower and utility rooms), additional overlay board protection should be considered, eg by a continuous flexible vinyl sheet flooring with welded joints, turned up at abutments and cove skirting.

## **Suspended timber floor (Figure 4)**

A.23 Insulation boards can be supported between timber joists using saddle clips or timber beads. Where timber beads are used, a void may be incorporated above the insulation to accommodate services, if required. For correct orientation of the product, see section 9.1.9.

A.24 Saddle clips are placed at intervals not exceeding 1 m along the timber floor joists. Where the product is to be installed on only one side of the joist, twin clips can be cut into single clips and nailed into place with galvanized nails.

A.25 If saddle clips are not used, the product may be retained using preservative-treated timber battens. The battens should be wide enough to retain the product in place and secured with corrosion-protected nails at a depth that will accommodate the thickness of the product.

A.26 The product should be cut to fit tightly between joists and pushed down onto the spikes of the saddle clips, or onto the beads. Small gaps should be insulated with cut strips of the product.

## Bibliography

- BRE Report BR 262 : 2002 *Thermal insulation: avoiding risks*
- BRE Report BR 443 : 2019 *Conventions for U-value calculations*
- BS 5250 : 2021 *Management of moisture in buildings. Code of practice*
- BS 8000-9 : 2003 *Workmanship on building sites — Cementitious levelling screeds and wearing screeds — Code of practice*
- BS 8102 : 2009 *Code of practice for protection of below ground structures against water from the ground*
- BS 8203 : 2017 *Code of practice for installation of resilient floor coverings*
- BS 8204-1 : 2003 + A1 : 2009 *Screeds, bases and in-situ floorings — Concrete bases and cement sand levelling screeds to receive floorings — Code of practice*
- BS 8204-2 : 2003 + A2 : 2011 *Screeds, bases and in-situ floorings — Concrete wearing surfaces — Code of practice*
- BS 8215 : 1991 *Code of practice for design and installation of damp-proof courses in masonry construction*
- BS 8417 : 2011 + A1 : 2014 *Preservation of wood — Code of practice*
- BS EN 300 : 2006 *Oriented Strand Boards (OSB) — Definitions, classification and specifications*
- BS EN 312 : 2010 *Particleboards — Specifications*
- BS EN 636 : 2012 + A1 : 2015 *Plywood — Specifications*
- BS EN 826 : 1996 *Thermal Insulating Products for Building Applications — Determination of Compression Behaviour*
- BS EN 1604 : 1997 *Thermal insulation products for building applications — Determination of dimensional stability under specified temperature and humidity conditions*
- NA to BS EN 1991-1-1 : 2002 *UK National Annex to Eurocode 1 : Actions on structures — General actions— Densities, self-weight, imposed loads for buildings*
- BS EN 1992-1-1 : 2004 + A1 : 2014 *Eurocode 2 : Design of concrete structures — General rules and rules for buildings*
- NA to BS EN 1992-1-1 : 2004 + A1 : 2014 *UK National Annex to Eurocode 2 : Design of concrete structures — General rules and rules for buildings*
- BS EN 12871 : 2013 *Wood-based panels — Performance specifications and requirements for load bearing boards for use in floors, walls and roofs*
- BS EN 13165 : 2012 + A2 : 2016 *Thermal insulation products for buildings — Factory made rigid polyurethane foam (PU) products — Specification*
- BS EN 13810-1 : 2002 *Wood-based panels — Floating floors — Performance specifications and requirements*
- BS EN 15037-1 : 2008 *Precast concrete products - Beam-and-block floor systems — Beams*
- BS EN 15037-2 : 2009 *Precast concrete products — Beam-and block floor systems — Concrete blocks*
- BS EN 15976 : 2011 *Flexible sheets for waterproofing. Determination of emissivity*
- BS EN ISO 9001 : 2015 *Quality management systems — Requirements*
- BS EN ISO 10456 : 2007 *Building materials and products — Hydrothermal properties — Tabulated design values and procedures for determining declared and design thermal values*
- CP 102 : 1973 *Code of practice for protection of buildings against water from the ground*
- DD CEN/TR 12872 : 2014 *Wood-based panels — Guidance on the use of load-bearing boards in floors, walls and roofs*
- DD CEN/TS 13810-2 : 2003 *Wood-based panels — Floating floors — Test methods*
- EN 13165 : 2012 + A2 : 2016 *Thermal insulation products for buildings — Factory made rigid polyurethane foam (PU) products — Specification*

PD CEN/TR 12872 : 2014 *Wood-based panels — Guidance on the use of load-bearing boards in floors, walls and roofs*

UNE-EN 13501-1 : 2019 *Fire classification of construction products and building elements — Part 1: Classification using test data from reaction to fire tests*



### Conditions

1 This Certificate:

- relates only to the product that is named and described on the front page
- is issued only to the company, firm, organisation or person named on the front page – no other company, firm, organisation or person may hold or claim that this Certificate has been issued to them
- is valid only within the UK
- has to be read, considered and used as a whole document – it may be misleading and will be incomplete to be selective
- is copyright of the BBA
- is subject to English Law.

2 Publications, documents, specifications, legislation, regulations, standards and the like referenced in this Certificate are those that were current and/or deemed relevant by the BBA at the date of issue or reissue of this Certificate.

3 This Certificate will be displayed on the BBA website, and the Certificate Holder is entitled to use the Certificate and Certificate logo, provided that the product and its manufacture and/or fabrication, including all related and relevant parts and processes thereof:

- are maintained at or above the levels which have been assessed and found to be satisfactory by the BBA
- continue to be checked as and when deemed appropriate by the BBA under arrangements that it will determine
- are reviewed by the BBA as and when it considers appropriate.

4 The BBA has used due skill, care and diligence in preparing this Certificate, but no warranty is provided.

5 In issuing this Certificate the BBA is not responsible and is excluded from any liability to any company, firm, organisation or person, for any matters arising directly or indirectly from:

- the presence or absence of any patent, intellectual property or similar rights subsisting in the product or any other product
- the right of the Certificate holder to manufacture, supply, install, maintain or market the product
- actual installations of the product, including their nature, design, methods, performance, workmanship and maintenance
- any works and constructions in which the product is installed, including their nature, design, methods, performance, workmanship and maintenance
- any loss or damage, including personal injury, howsoever caused by the product, including its manufacture, supply, installation, use, maintenance and removal
- any claims by the manufacturer relating to UKCA marking and CE marking.

6 Any information relating to the manufacture, supply, installation, use, maintenance and removal of this product which is contained or referred to in this Certificate is the minimum required to be met when the product is manufactured, supplied, installed, used, maintained and removed. It does not purport in any way to restate the requirements of the Health and Safety at Work etc. Act 1974, or of any other statutory, common law or other duty which may exist at the date of issue or reissue of this Certificate; nor is conformity with such information to be taken as satisfying the requirements of the 1974 Act or of any statutory, common law or other duty of care.